



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION III
1650 Arch Street
Philadelphia, Pennsylvania 19103-2029

Mr. Joseph Ditty
Pretreatment Coordinator
Municipal Sanitary Authority for the City of New Kensington
120 Logans Ferry Road
New Kensington, Pennsylvania 15068-2046

Re: Pretreatment 2009 Annual Report
NPDES No. PA0027111

Dear Mr. Ditty:

Thank you for your timely response to the 2009 annual report review letter. As a result of your response, there were a few changes that had to be made to the Measures Sheet-which is attached to this letter.

Measure No. 3 - Sludge Results – Based upon the revised sludge data, Category 2 is assigned for zinc because one of the four sample results exceeded the sludge goal and nickel was changed to Category 3 because all four of the sampling results exceeded the sludge goal.

Measure No. 4 - Data/local limits Evaluation – Category 3 is assigned to nickel, TSS and zinc due to sludge and effluent goal exceedances.

Measure No. 19 - Overall Program rating – The overall rating for 2009 changed from 85.2% to **83.3%**. The rating remains designated as Category 2.

If you have any questions regarding this matter, please contact me at 215-814-5783 or email ottinger.elizabeth@epa.gov.

Sincerely,

Elizabeth Ottinger
NPDES Permits and Enforcement (3WP41)
Water Protection Division

Enclosures

cc: Sam Harper, PADEP Southwest Region (w/out enclosures)
Linda French, Hatch Mott MacDonald (w/ enclosures)